

August 27, 2013

Odyssey Wallcoverings
60 Prince Andrew Place
Toronto, Ontario
Canada M3C 2H4

To Whom It May Concern:

This will certify that pattern Imperia (ODY1232-1248), produced with *Second-Look* construction, is Class A Fire Rated and meets or exceeds all Type II requirements of CCC-W-408A/D, and Industry Voluntary Standard CFFA-W-101A/D.

Performance Specifications

| | |
|--------------------------|------------------------------------|
| Total Weight | 20 oz./ly (452 gr/m ²) |
| Width | 52/54" (132/137 cm) |
| Fabric | Osnaburg |
| Breaking Strength (Avg.) | 115 x 100 |
| Tear Strength (Avg.) | 55 x 75 |



Fire Hazard Classification

Passes NFPA 286 Corner Burn

| | Flame Spread | Smoke Density Factor |
|-----------------|--------------|----------------------|
| ASTM E-84 | 15 | 20 |
| CAN/ULC S102-07 | 25 | 25 |

Second-Look®

- Contains 20% recycled content by weight
- Minimum 10% post-consumer

LSI Wallcovering